








ZB RoCon U1 - COF







- >DE< SW Nr Regler
- >GB< SW Nr Controller
- >FR< SW Nr Controller
- >BE< SW Nr Controller
- >IT< SW Nr Controller
- >ES< SW Nr Controller
- >PT< SW Nr Controller



- I**
- Rev.: 00 T
 - 00 V
 - 00 W
 - 00 Y
 - 01 A
 - 01 D






- >DE< Installation
- >GB< Setup
- >FR< Mise en service
- >BE< Inbedrijfning
- >IT< Messa in Servizio
- >ES< Instalación
- >PT< Instalação



- >DE< AUS
- >GB< Off
- >FR< Inactif
- >BE< Uit
- >IT< Off
- >ES< Cerrado
- >PT< Fechado


- >DE< Ein
- >GB< On
- >FR< Actif
- >BE< Aan
- >IT< On
- >ES< Abierto
- >PT< Aberto



- >DE< RoCon U1 Zuord
- >GB< RoCon U1 assign
- >FR< RoCon U1 Pos
- >BE< RoCon U1 Pos
- >IT< RoCon U1 Pos
- >ES< RoCon U1 Pos
- >PT< RoCon U1 Pos

- >DE< Wohnraum
- >GB< Living Room
- >FR< Living Room
- >BE< Living Room
- >IT< Living Room
- >ES< Living Room
- >PT< Living Room





ZB RoCon U1 - COF

4.

>DE< Kühlen
 >GB< Cooling
 >FR< Mode froid
 >BE< koelen
 >IT< Raffreddare
 >ES< Refrigerar
 >PT< Arrefecimento

ROTEX

ROTEX
RoCon HP, RoCon U1,
RoCon M1

CE

08/2013

008.14 147 XX_04

5.

3.4.3

18 FA ROTEX RoCon HP


6.

>DE< HZK Konfig
 >GB< HC Configuration
 >FR< Config circuit chauf
 >BE< Config. verwarming
 >IT< Config. Circ.Risc.
 >ES< Circ calefac config
 >PT< Circ calefac config

>DE< Raum-Soll Start K
 >GB< T-Room start cooling
 >FR< T-Room start cooling
 >BE< T-Room start cooling
 >IT< T-Room start cooling
 >ES< T-Room start cooling
 >PT< T-Room start cooling

>DE< Raum-Soll Max K
 >GB< T-Room max cooling
 >FR< T-Room max cooling
 >BE< T-Room max cooling
 >IT< T-Room max cooling
 >ES< T-Room max cooling
 >PT< T-Room max cooling

>DE< Kùhlsollwert Korr
 >GB< Cooling Setpoint Adj
 >FR< Corr val cons Rafr
 >BE< Corr. setpunt koelen
 >IT< Corr. Val. Rafredd
 >ES< Val nom enfr Corr
 >PT< Corr setpoint Arref





For example:

(A) = 24°C
 (B) = 35°C
 (C) = 24°C
 (D) = 28°C

(E) = +5K
 $T_A = 28°C$
 $\Rightarrow T_{R,Sx} = 30,5°C$

ROTEX




ZB RoCon U1 - COF




SW Nr Regler / Controller
366
Rev.: 01 G ✓

RoCon BM1 (Rev.: ≥ 01 G)




1.



- >DE< Kühlen
- >GB< Cooling
- >FR< Mode froid
- >BE< koelen
- >IT< Raffreddare
- >ES< Refrigerar
- >PT< Arrefecimento

2.



Installation
Codenummer
RoCon U1 Zuord
PWMKonfig


- >DE< RoCon U1 Zuord
- >GB< RoCon U1 assign
- >FR< RoCon U1 Pos
- >BE< RoCon U1 Pos
- >IT< RoCon U1 Pos
- >ES< RoCon U1 Pos
- >PT< RoCon U1 Pos

RoCon U1 Zuord
Wohnraum

- >DE< Wohnraum
- >GB< Living Room
- >FR< Living Room
- >BE< Living Room
- >IT< Living Room
- >ES< Living Room
- >PT< Living Room

RoCon U1 Zuord

3.




Raumsoll Tag
T-RaumSoll 1
T-RaumSoll2

- >DE< T-Raum Soll 1
- >GB< T-Room 1 Setpoint
- >FR< T-ambiente 1
- >BE< T-ruimte gew 1
- >IT< T-Ambiente 1
- >ES< T-Ambiente Teor 1
- >PT< T-Amb 1 Setpoint

T-RaumSoll 1
20.0 °C
5°C — 40°C

T-RaumSoll 1



Subject to change and correction
Vergissingen en technische wijzigingen voorbehouden
Salvo errori e con riserva di modifiche tecniche
Reservado el derecho de error y modificaciones técnicas
Sous réserves d'erreurs et de modifications techniques
Sob reserva de erros e de modificações técnicas

a member of **DAIKIN** group

ROTEX

ROTEX Heating Systems GmbH

Langwiesenstraße 10

D-74363 Güglingen

Fon +49 (71 35) 103-0

Fax +49 (71 35) 103-200

e-mail info@rotex.de

www.rotex.de