

outdoor unit indoor unit

UU09W ULD / CB09L N12

Function (indicate if present)	
cooling	Y
heating	Y

Item	symbol	value	unit
Design load			
cooling	Pdesignc	2.5	kW
heating / Average	Pdesignh	2.8	kW
heating / Warmer	Pdesignh	x,x	kW
heating / Colder	Pdesignh	x,x	kW

Declared capacity* for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj			
Tj=35°C	Pdc	2.5	kW
Tj=30°C	Pdc	1.9	kW
Tj=25°C	Pdc	1.6	kW
Tj=20°C	Pdc	1.5	kW

Declared capacity* for heating / Average climate, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	2.4	kW
Tj=2°C	Pdh	1.5	kW
Tj=7°C	Pdh	1.0	kW
Tj=12°C	Pdh	1.1	kW
Tj=bivalent temperature	Pdh	2.8	kW
Tj=operating limit	Pdh	2.8	kW

Declared capacity* for heating / Warmer climate, at indoor temperature 20°C and outdoor temperature Tj			
Tj=2°C	Pdh	x,x	kW
Tj=7°C	Pdh	x,x	kW
Tj=12°C	Pdh	x,x	kW
Tj=bivalent temperature	Pdh	x,x	kW
Tj=operating limit	Pdh	x,x	kW

If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.	
Average (mandatory)	Y
Warmer (if designated)	N
Colder (if designated)	N

Item	symbol	value	unit
Seasonal efficiency			
cooling	SEER	5.1	-
heating / Average	SCOP/A	3.8	-
heating / Warmer	SCOP/W	x,x	-
heating / Colder	SCOP/C	x,x	-

Declared Energy efficiency ratio* for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj			
Tj=35°C	EERd	3.4	-
Tj=30°C	EERd	4.7	-
Tj=25°C	EERd	7.6	-
Tj=20°C	EERd	8.8	-

Declared Coefficient of performance* for heating / Average climate, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	COPd	2.5	-
Tj=2°C	COPd	3.7	-
Tj=7°C	COPd	4.5	-
Tj=12°C	COPd	5.2	-
Tj=bivalent temperature	COPd	2.3	-
Tj=operating limit	COPd	2.3	-

Declared Coefficient of performance* / Warmer climate, at indoor temperature 20°C and outdoor temperature Tj			
Tj=2°C	COPd	x,x	-
Tj=7°C	COPd	x,x	-
Tj=12°C	COPd	x,x	-
Tj=bivalent temperature	COPd	x,x	-
Tj=operating limit	COPd	x,x	-

Declared capacity* for heating / Colder climate, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	Pdh	x,x	kW
Tj=2°C	Pdh	x,x	kW
Tj=7°C	Pdh	x,x	kW
Tj=12°C	Pdh	x,x	kW
Tj=bivalent temperature	Pdh	x,x	kW
Tj=operating limit	Pdh	x,x	kW
Tj=-15°C	Pdh	x,x	kW

Bivalent temperature			
heating / Average	Tbiv	-10	°C
heating / Warmer	Tbiv	X	°C
heating / Colder	Tbiv	X	°C

Cycling interval capacity			
for cooling	Pcyc	x,x	kW
for heating	Pcyc	x,x	kW

Degradation cooling**	co-efficient Cdc	0.25	-
-----------------------	------------------	------	---

Electric power input in power modes other than 'active mode'			
off mode	P _{OFF}	0.007	kW
standby mode	P _{SB}	0.007	kW
thermostat-off mode	P _{TO}	0.031	kW
crankcase heater mode	P _{CK}	0	kW

Capacity control (indicate one of three options)			
fixed	N		
staged	N		
variable	Y		

Contact details for obtaining more information

Name : Christianna Papazahariou
 Position : European Regulatory Manager
 E-mail address : chris.papazahariou@lge.com
 Tel. 01 49 89 57 41 – 06 83 077 455
 Postal address : Paris Nord II – 117 avenue des Nations BP 59372 Villepinte – 95942 Roissy CDG Cedex
www.lg.com

Declared Coefficient of performance* / Colder climate, at indoor temperature 20°C and outdoor temperature Tj			
Tj=-7°C	COPd	x,x	-
Tj=2°C	COPd	x,x	-
Tj=7°C	COPd	x,x	-
Tj=12°C	COPd	x,x	-
Tj=bivalent temperature	COPd	x,x	-
Tj=operating limit	COPd	x,x	-
Tj=-15°C	COPd	x,x	-

Operating limit temperature			
heating / Average	Tol	-10	°C
heating / Warmer	Tol	x	°C
heating / Colder	Tol	x	°C

Cycling interval efficiency			
for cooling	EERcyc	x,x	-
for heating	COPcyc	x,x	-

Degradation heating**	co-efficient Cdh	0.25	-
-----------------------	------------------	------	---

Annual electricity consumption			
cooling	Q _{CE}	172	kWh/a
heating / Average	Q _{HE}	1032	kWh/a
heating / Warmer	Q _{HE}	X	kWh/a
heating / Colder	Q _{HE}	X	kWh/a

Other items			
Sound power level (indoor/outdoor)	level L _{WA}	49 / 56	dB(A)
Global warming potential	GWP	2087.5	kgCO ₂ eq.
Rated air flow (indoor/outdoor)	-	540/1920	m ³ /h

*= For staged capacity units, two values divided by a slash (/) will be declared in each box in the section "Declared capacity of the unit" and "declared EER/COP" of the unit.
 **= If default Cd=0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.

