

The technical documentation

1. General description

Models:

MV-F09BI

2. Reference to harmonised standards: EN 14825:2016、EN 14511-2:2013、EN 14511-3:2013、EN 12102-1:2017

3. Specific precautions that shall be taken when the model is assembled, installed, maintained or tested:

- ① According to the directions of Operating Instruction Manual.
- ② Set the guide vane of air outlet at middle position by hand to achieve maximum air volume.
- ③ Set upper guide louver at the appropriate position to achieve maximum air volume.
- ④ Press any button during the testing mode, the unit will exit the lock frequency, you need repeat the process to enter testing mode if needed!
- ⑤ After each test a condition, need to power off and test the next working condition !

4. Measured technical parameters & 5. The calculations performed with the measured parameters & 6. Testing conditions

Information requirements

(the number of decimals in the box indicates the precision of reporting)

Information to identify the model(s) to which the information relates to:

Function (indicate to which function information applies)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
cooling	Y			Average (mandatory)	Y		
heating	Y			Warmer (if designated)	N		
				Colder (if designated)	N		
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
cooling	P _{design c}	5,2	kW	cooling	Test SEER	5,15	—
heating/Average	P _{design h}	3,8	kW	heating/Average	SCOP(A)	3,80	—
heating/Warmer	P _{design h}	x,x	kW	heating/Warmer	SCOP(W)	x,xx	—

heating/Colder	P _{design h}	x,x	kW	heating/Colder	SCOP(C)	x,xx	—
Tested capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature T _j				Tested energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature T _j			
T _j = 35 °C	P _{tc}	5,20	kW	T _j = 35 °C	EER	3,33	—
T _j = 30 °C	P _{tc}	3,67	kW	T _j = 30 °C	EER	4,08	—
T _j = 25 °C	P _{tc}	2,49	kW	T _j = 25 °C	EER	6,40	—
T _j = 20 °C	P _{tc}	1,62	kW	T _j = 20 °C	EER	8,50	—
Tested capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature T _j				Tested coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature T _j			
T _j = - 7 °C	P _{th}	3,34	kW	T _j = - 7 °C	COP	2,81	—
T _j = 2 °C	P _{th}	2,03	kW	T _j = 2 °C	COP	3,85	—
T _j = 7 °C	P _{th}	1,36	kW	T _j = 7 °C	COP	4,46	—
T _j = 12 °C	P _{th}	1,34	kW	T _j = 12 °C	COP	5,59	—
T _j = bivalent temperature	P _{th}	3,34	kW	T _j = bivalent temperature	COP	2,81	—
T _j = operating limit	P _{th}	2,74	kW	T _j = operating limit	COP	2,37	—
Tested capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature T _j				Tested coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature T _j			
T _j = 2 °C	P _{th}	x,x	kW	T _j = 2 °C	COP	x,x	—
T _j = 7 °C	P _{th}	x,x	kW	T _j = 7 °C	COP	x,x	—
T _j = 12 °C	P _{th}	x,x	kW	T _j = 12 °C	COP	x,x	—
T _j = bivalent temperature	P _{th}	x,x	kW	T _j = bivalent temperature	COP	x,x	—
T _j = operating limit	P _{th}	x,x	kW	T _j = operating limit	COP	x,x	—
Tested capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature T _j				Tested coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature T _j			
T _j = - 7 °C	P _{th}	x,x	kW	T _j = - 7 °C	COP	x,x	—

T _j = 2 °C	P _{th}	x,x	kW	T _j = 2 °C	COP	x,x	—
T _j = 7 °C	P _{th}	x,x	kW	T _j = 7 °C	COP	x,x	—
T _j = 12 °C	P _{th}	x,x	kW	T _j = 12 °C	COP	x,x	—
T _j = bivalent temperature	P _{th}	x,x	kW	T _j = bivalent temperature	COP	x,x	—
T _j = operating limit	P _{th}	x,x	kW	T _j = operating limit	COP	x,x	—
T _j = - 15 °C	P _{th}	x,x	kW	T _j = - 15 °C	COP	x,x	—
Bivalent temperature				Operating limit temperature			
heating/Average	T _{biv}	-7	°C	heating/Average	T _{ol}	-10	°C
heating/Warmer	T _{biv}	x	°C	heating/Warmer	T _{ol}	x	°C
heating/Colder	T _{biv}	x	°C	heating/Colder	T _{ol}	x	°C
Power consumption of cycling				Efficiency of cycling			
cooling	P _{cyc}	x,x	kW	cooling	EER _{cyc}	x,x	—
heating	P _{ych}	x,x	kW	heating	COP _{cyc}	x,x	—
Degradation co-efficient cooling (**)	C _{dc}	0,25	—	Degradation co-efficient heating (**)	C _{dh}	0,25	—
Electric power input in power modes other than 'active mode'				Seasonal electricity consumption			
off mode	P _{OFF}	0,00871	kW	cooling	Q _{CE}	353,00	kWh/a
standby mode	P _{SB}	0,00871	kW	heating/Average	Q _{HE}	1398,00	kWh/a
thermostat-off mode	P _{TO}	0.03855/0.01754	kW	heating/Warmer	Q _{HE}	x	kWh/a
crankcase heater mode	P _{CK}	0,00	kW	heating/Colder	Q _{HE}	x	kWh/a
Capacity control (indicate one of three options)				Other items			
fixed		N		Sound power level (indoor/outdoor)	LWA	54/65	dB(A)
staged		N		Global warming potential	GWP	675	kgCO ₂ eq.

variable	Y	Rated air flow (indoor/outdoor)	—	700/450/2600	m ³ /h
----------	---	------------------------------------	---	--------------	-------------------